

Building 4001 Pumping Station Bypass
Questions Answers
MR-16-029946

No.	Question	Answer
1	Should the cost associated with the required training, Parkworker, Rad Worker II, and Spotter training be included in the Pre-Mobilization Submittal price line, Exhibit c, Form A?	Refer to Exhibit C, Form A-2, Measurement for Payment, Pay Item 4.0 Mobilization
2	Are we to include Exhibit C Form G with our proposal?	Yes - refer to Instructions to Offerors, 24 - Proposal Volumes and 32.A. - Qualification Criteria
3	Are we to include Exhibit C Form G for our lower tier subcontractors with our proposal?	Yes - refer to Instructions to Offerors, 24 - Proposal Volumes and 32.A. - Qualification Criteria
4	Is Microsoft Project acceptable format for schedules submittal?	Yes
5	Is it a requirement to have an "Architect of Record" for the design?	No. Refer to Exhibit D Scope of Work, Section 2.2 System Design.
6	Are we to include a conceptual design with our proposal?	No. Refer to Instructions and Information to Offerors, Section 23. Proposal Volumes
7	Is Rad Worker II training required for the personal that will be performing the design work?	Procedurally, Untrained personnel performing design work may access controlled areas, underground radioactive materials areas, soil contamination areas and fixed contamination areas unescorted for short duration visits less than approximately 40 hours per calendar year. However the STR will require untrained personnel performing design functions to be escorted during site visits.
8	May the new pipe be joined by flanges instead of butt welding?	Sections of pipe may be welded together off-site and the sections then joined together on site with approved flanges.
9		
10		
14		
15		
16		
17		
18		
21		
22		
23		
24		